



**DISABILITY  
LAW  
CENTER**

# ADA Checklist

## BUS STOPS

205 North 400 West ▪ Salt Lake City, Utah ▪ 84103  
(800) 662-9080 ▪ (800) 550-4182 TTY ▪ [www.disabilitylawcenter.org](http://www.disabilitylawcenter.org)

**Bus Stop Name** \_\_\_\_\_

Access

<b>Bus Stop Pad (ADAAG 10.2, 10.2.1)</b>	<b>Yes</b>	<b>No</b>
Is the bus stop pad where a lift or ramp is deployed stable and firm?		
Does the bus stop pad have a clear length of at least 96 inches (measured from the curb or vehicle roadway) and a clear width of at least 60 inches (parallel to the roadway)?  <b>Clear length:</b> <b>Clear width:</b>		
Is the bus pad connected to streets, sidewalks or pedestrian paths by a stable, firm and slip-resistant route that is at least 36 inches wide?  <b>Width:</b>		
Is the slope of the bus pad parallel to the roadway and, to the extent practicable, the same as that of the roadway?  A maximum slope of 1:50 perpendicular to the roadway is allowed for water drainage.  <b>Slope:</b>		
<b>Bus Shelter (ADAAG 10.2.1)</b>	<b>Yes</b>	<b>No</b>
Can a person in a wheelchair enter the bus shelter from the public way and reach a location having a clear floor area of 30 inches by 48 inches, entirely within the shelter?  <b>Clear area:</b>		
Are the bus shelters connected by a stable, firm and slip-resistant route that is at least 36 inches wide?  <b>Width:</b>		
<b>New Route Signs (ADAAG 10.2.1)</b>	<b>Yes</b>	<b>No</b>
Do new signs identifying bus routes apply with signage requirements? <ul style="list-style-type: none"> <li>• Mounted on wall adjacent to latch side of door, or as close as possible.</li> <li>• Brailled text of the same information.</li> <li>• If pictogram is used, it must be accompanied by raised characters and Braille.</li> <li>• Signs mounted with centerline 60 inches from floor.</li> </ul>		

<b>Height:</b>		
----------------	--	--

**Access to Rest Rooms**

<b>Getting to the Rest Rooms (ADAAG 4.1)</b>	<b>Yes</b>	<b>No</b>
If rest rooms are available to the public, is at least one rest room (either one for each sex or unisex) fully accessible?		
Are there signs at inaccessible rest rooms that give directions to accessible ones?		
<b>Doorways and Passages (ADAAG 4.2, 4.13, 4.3)</b>	<b>Yes</b>	<b>No</b>
Is there tactile signage identifying rest rooms?  Mount signs on the wall, on the latch side of the door, complying with the requirements for permanent signage.		
Are pictograms or symbols used to identify rest rooms, and, if used, are raised characters and Braille included below them?		
Is the doorway at least 32 inches clear?  <b>Clear width:</b>		
Are doors equipped with accessible handles (operable with a closed fist), 48 inches high or less?  <b>Height:</b>		
Can doors be opened easily (5 lbf maximum force)?  <b>Force:</b>		
Does the entry configuration provide adequate maneuvering space for a person using a wheelchair?  A person in a wheelchair needs 36 inches of clear width for forward movement, and a 5-foot diameter or T-shaped clear space to make turns. A minimum distance of 48 inches clear of the door swing is needed between the two doors of an entry vestibule.  <b>Clear width:</b>		
Is there a 36-inch-wide path to all fixtures?  <b>Width:</b>		
<b>Stalls (ADAAG 4.17)</b>	<b>Yes</b>	<b>No</b>
Is the stall door operable with a closed fist, inside and out?		
Is there a wheelchair-accessible stall that has an area of at least 5 feet by 5 feet, clear of the door swing, OR is there a stall that is less accessible but that provides greater access than a typical stall (either 36 by 69 inches or 48 by 69 inches)?  <b>Length:</b> <b>Width:</b>		
In the accessible stall, are there grab bars behind and on the side wall nearest to the toilet?		
Is the toilet seat 17 to 19 inches high?  <b>Height:</b>		
<b>Lavatories (ADAAG 4.19, 4.24)</b>	<b>Yes</b>	<b>No</b>
Does one lavatory have a 30-inch-wide by 48-inch-deep clear space in front?  A maximum of 19 inches of the required depth may be under the lavatory.		

<b>Clear space:</b>		
Is the lavatory rim no higher than 34 inches? <b>Height:</b>		
Are there at least 29 inches from the floor to the bottom of the lavatory apron (excluding pipes)? <b>Height:</b>		
Can the faucet be operated with one closed fist?		
Are soap and other dispensers and hand dryers within reach ranges and usable with one closed fist?		
Is the mirror mounted with the bottom edge of the reflecting surface 40 inches high or lower? <b>Height:</b>		

**Additional Access**

<b>Drinking Fountains (ADAAG 4.15)</b>	<b>Yes</b>	<b>No</b>
Is there at least one fountain with clear floor space of at least 30 by 48 inches in front? <b>Clear space:</b>		
Is there one fountain with its spout no higher than 36 inches from the ground and another with a standard height spout (or a single “hi-lo” fountain)? <b>Height:</b>		
Are controls mounted on the front or on the side near the front edge and operable with one closed fist?		
Is each fountain cane-detectable (located within 27 inches of the floor or protruding in the circulation space less than 4 inches from the wall)? <b>Height:</b> <b>Protrusion:</b>		
<b>Telephones (ADAAG 4.31)</b>	<b>Yes</b>	<b>No</b>
If pay or public use phones are provided, is there clear floor space of at least 30 by 48 inches in front of at least one? <b>Clear space:</b>		
Is the highest operable part of the phone no higher than 48 inches (up to 54 inches if a side approach is possible)? <b>Height:</b>		
Does the phone protrude no more than 4 inches into the route of travel? <b>Protrusion:</b>		
Does the phone have push-button controls?		
Is the phone hearing-aid compatible?		
Is the phone adapted with volume control?		
Is the phone with volume control identified with appropriate signage?		
If there are four or more public phones in the building, is one of the phones equipped with a text telephone (TT or TDD)?		
Is the location of the text telephone identified by accessible signage bearing the international TDD symbol?		